#### SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

#### MEMORANDUM

DATE:

August 29, 2012

TO:

Brian Yeh

FROM:

Rudy Eden 2

**SUBJECT:** 

Evaluation of Source Test Report: (Requested by Raj Singh, August 3, 2012)

AQMD ID:

FACILITY ID NO. 152952

APPLICATION NO.: 530180, 495681

COMPANY:

SA Recycling LLC DBA SA Recycling of LA, Terminal Island

EQUIPMENT:

Regenerative Thermal Oxidizer (RTO)

Scrap Metal Shredder

TEST LOCATION:

901 New Dock St., Terminal Island, CA 90731

TEST DATE:

June 18-20, 2012

REFERENCE: PR 12144 (STE Source Test File)

Source Test Engineering has completed the evaluation of the subject source test report and has concluded that it is:

#### CONDITIONALLY ACCEPTABLE

Compliance with all applicable Rules and/or Permit Conditions, as well as compliance limits, may not have been acceptably demonstrated, and/or the accuracy of some of the reported gaseous emissions and/or flows may not have been confidently confirmed, and their use regarding emission calculations may be subject to certain restrictions. Refer to the following sections for a complete discussion concerning these restrictions and compliance determination.

The attached evaluation has not been forwarded to the facility or the source testing firm. It is the responsibility of the requestor to review the attached evaluation and forward it to the parties involved, if you concur with our findings. If there are any questions, please contact Michael Cecconi at Ext. 2244.

MG:MAC Attachment cc: Mike Garibay

Raj Singh

12144rep SA Recycling RTO: REV 8/8/12

#### SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

MONITORING & ANALYSIS DIVISION \* SOURCE TEST ENGINEERING BRANCH

#### SOURCE TEST REPORT EVALUATION

PR 12144 S/T ID: AQMD ID: FACILITY ID NO. 152952 A/N: 530180, 495681 SA Recycling LLC DBA SA Recycling of LA, Terminal Island COMPANY: Regenerative Thermal Oxidizer (RTO) EQUIPMENT: Scrap Metal Shredder 901 New Dock St., Terminal Island, CA 90731 LOCATION: Raj Singh (Memo Dated August 3, 2012) REQUESTED BY: PERFORMANCE/COMPLIANCE REPORT TYPE OF TEST: DOCUMENT DATE: July 25, 2012 REASON FOR TEST: (TESTING SUBJECT TO THE FOLLOWING RULE, PERMIT, OR SPECIFIED CONDITIONS): - NOx - 60 ppm @3% O<sub>2</sub> or 0.073 lb/MM BTU during startup - VOC - 95% Destruction Efficiency CO, NOx, VOC, Speciated Organics, Multiple Metals, Acid Gases, PM<sub>10</sub> REQUESTED EVAL: June 18-20, 2012 TEST DATE: TEST FIRM: Professional Environmental Services Michael Cecconi EXT: 2244 STE EVALUATOR: REVIEW DATE: August 29, 2012

**OVERVIEW OF EVALUATION:** 

**OVERALL** CONFIDENCE IN ☐ ACCEPTABLE UNACCEPTABLE REPORTED TEST **ACCEPTABLE** RESULTS: NOx adjusted emissions should only be used for compliance determination and must not be used for emission calculations such as emission rates (lb/hr) or emission credits (lb/day) or for RESTRICTIONS FOR determination of emission factors (such as lb/MM SCF of natural USE OF REPORTED gas, g/bhp-hr, or ppm  $@0\% O_2$ ). RESULTS: CO, VOC, Speciated Organics, Multiple Metals, Acid Gases, PM10 reported emissions may be used for compliance determination and emission calculations. CO, VOC, Speciated Organics, Multiple Metals, Acid Gases, PM10 emissions, as reported, are in compliance by an acceptable margin with the Rules/Permit Compliance Limits specified above. COMPLIANCE DETERMINATION: NOx emissions, as adjusted (see next section of this evaluation), are in compliance by an acceptable margin<sup>2</sup> with the Rules/Permit Compliance Limits specified above.

(REFER TO NEXT SECTION FOR COMPLETE DISCUSSION OF TEST RESULTS AND CORRECTED EMISSION INFORMATION, IF APPLICABLE)

<sup>&</sup>lt;sup>1</sup> NOTE: STE assigns a 10% "margin of error" to most emission rates when evaluating emissions for compliance determination. This is due to uncertainties assigned to source testing, in general, and errors associated with individual analytical procedures. As a result, some reported emissions may be judged as being in compliance although they appear to be non-compliant or marginally non-compliant. Similarly, non-compliance is judged using the same margin-of-error.

<sup>&</sup>lt;sup>2</sup> NOTE: STE assigns a 10% "margin of error" to most emission rates when evaluating emissions for compliance determination. This is due to uncertainties assigned to source testing, in general, and errors associated with individual analytical procedures. As a result, some reported emissions may be judged as being in compliance although they appear to be non-compliant or marginally non-compliant. Similarly, non-compliance is judged using the same margin-of-error.

·D	EDO	DT	REV	EW

#### SOUR'CE TEST REPORT EVALUATION

#### DETAILED REVIEW

This source test report has been reviewed by the Evaluations Unit staff. The following specifically explains the restrictions concerning the treatment of the reported source test information:

	Completeness of Application/Protocol/Report
$\boxtimes$	Representativeness of Data & Process
	Rule/Permit Fulfillment
	Sampling & Analytical Methods
	Quality Assurance
$\boxtimes$	Calculations

#### REPRESENTATIVENESS OF DATA & PROCESS

Some of the reported gaseous emissions fell short of established analytical standards, and they have been recalculated upward to default levels for qualitative compliance determination only. This applies to reported NOx concentrations and mass emissions. AQMD regards the valid reporting range of measurement of a Method 100.1 gas analyzer as being 20-95% of the instrument full-scale-range (FSR). Since the tester used a very low concentration calibration gas (0.4 ppm), gas measurements (as measured at the stack) falling below this lower limit were adjusted upward to the 10% FSR value for gas concentration Rule/Permit Compliance limit determination only. Adjusted NOx values cannot be used quantitatively for mass emission or emission factor calculations because they are probably overstated. See the "Calculations" section for the NOx emissions.

#### **CALCULATIONS**

- The tester made a small error in calculating the PM emission rate for the RTO scrubber exhaust. The tester corrected the emission rate to 1.00 lb/hr as shown on the revised calculation sheet dated August 23, 2012.
- The tester calculated the VOC emission rate (lb/hr) for the RTO scrubber exhaust as carbon. The tester corrected the emission rate to 0.89 lb/hr as methane as shown on the revised calculation sheet dated August 23, 2012.
- The adjusted **NOx** emission rates are as follows:

RTO Startup 2.5 ppm

RTO Scrubber Exhaust

2.5 ppm 0.478 lb/hr 0.78 lb/hr

0.052 lb/MMBTU

#### **SOURCE TEST REPORT:**

#### COMPLIANCE TESTING OF AN AIR POLLUTION CONTROL SYSTEM SA RECYCLING TERMINAL ISLAND FACILITY

Conducted At:

#### SA RECYCLING

901 New Dock Street Terminal Island, CA 90731

Prepared For:

#### YORKE ENGINEERING, LLC

31726 Rancho Viejo Road, Suite 218. San Juan Capistrano, California 92675

Conducted On:

June 18, 19 and 20, 2012

Submitted On: July 25, 2012

Project No: 1234.010

Prepared By:

### PROFESSIONAL ENVIRONMENTAL SERVICES, INC. 5027 Irwindale Avenue, Suite 100

Irwindale, California 91706

#### TABLE 1

#### SUMMARY OF NOX, CO AND TGNMNEO DATA AIR POLLUTION CONTROL SYSTEM SA RECYCLING TERMINAL ISLAND FACILITY

Conducted On: June 18, 2012

Parameter:		RTO Inlet	RTO 1	Compliance
	RTO	,	Scrubber	Limit
	Start-up		Exhaust	
NOx: 25 Pan	*(A* )			
ppm (v/v) ''	1.16 2.5		0.64 2.5	7
lbs/lır <sup>2</sup>	0.222 0.478		0.20 0.78	
lbs/MMBtu	0.024 0,052		NA	0.073
	1000	7	1/2 17 78.	
CO:				
ppm (v/v)	202	SOPAMI	25.1	Control of the Contro
lbs/hr	23.46		4.84	
Mark Mark Control	ر در			
TGNMNEO:				
ppm (v/v) <sup>3</sup>		391	8.1	9,95 DDM 83
lbs/hr_	100000000000000000000000000000000000000	28.5 as C	10.68 as C	
Efficiency (%)	A CASE OF BELLEVILLE		(0.89 qu'CH	97.6
Fuel Data:		- 5 3 3 3	7.77	96 1.25
Natural gas rate (scfh)	8,841	NA	NA	100
Heat inputMMBtu/hr) 4	9.28	NA	NA	
Flow (dscfm)	26,470	38,707	43,405	
O <sub>2</sub> (%)	19.04	20.8	20.4	
CO2 (%)	0.90	0.47	0.38	

<sup>&</sup>lt;sup>1</sup> RTO Scrubber data for NOx and CO are based on the average of three test runs each one hour in duration.

<sup>2</sup> Mass emissions are based on velocity traverses conducted at the scrubber exhaust.

<sup>4</sup> Heat input based on RTO natural gas meter readings during testing and a fuel heating value of 1,050 Btu/cf.

9.16x1. UEX

<sup>&</sup>lt;sup>3</sup> TGNMNEO data based on the average of duplicate samples at the inlet location and the highest value of duplicate samples at the scrubber exhaust since the variation between samples was greater than 20% per SCAQMD Method 25.3.

#### TABLE 2

. .

#### SUMMARY OF PARTICULATE MATTER DATA AIR POLLUTION CONTROL SYSTEM SA RECYCLING TERMINAL ISLAND FACILITY

Conducted On: June 19, 2012

Parameter:	RTO Inlet	RTO Scrubber Exhaust	
Total Particulate Matter			
grains/dscf	0.0056	0.0027	
lbs/hr	1.782	-1:016	1,002
Exhaust Flow			
Flow (dscfm)	37,235	43,625	

Swel pro

Swel pro

Scrubben.

# TABLE 3 SUMMARY OF TRACE ELEMENT DATA AIR POLLUTION CONTROL SYSTEM SCRUBBER EXHAUST SA RECYCLING TERMINAL ISLAND FACILITY Conducted On: June 18-19, 2012

Parameter:	Run No. 1	Run No. 2	Run No. 3	Average
Antimony		3.2.2.2.		
ug/m³	0.11	0.11	ND	<0.11
lbs/hr	0.000018	0.000018	ND	<0.000018
Arsenic				0.000018
ug/m³	0.29	0.08	0.42	0.26
lbs/hr	0.000047	0.000012	0.000069	0.000043
Barium			7 7 7 7 7 7 7 7 7 7	
ug/m³	1.23	1.43	135.79	46.15
lbs/hr	0.000199	0.000233	0.022056	0.007496
Beryllium				7: 7:
ug/m³	ND	ND	ND	ND
lbs/hr	ND	ND	ND	ND
Cadmium	St. or Market St. Com.	ing the street of the street o	AD .	ND
ug/m³	0.11	0.11	0.07	0.10
lbs/hr	0.000018	0.000019	0.000012	
Chromium		0.000019	0.000012	0.000016
ug/m³	0.58	0.56	4.40	1.05
lbs/hr	0.000094	0.000092		1.85
Cobalt		0.000092	0.000715	0.00030
ug/m³	0.23	0.20	0.00	
lbs/hr	0.000038	0.000032	0.29	0.24
Copper	0.000030	0.00032	0.000048	0.000039
ug/m³	1.99	5.07	0.50	0.000057
lbs/hr	0.000322		0.53	2.53
Lead	0.000322	0.000827	0.000086	0.000412
ug/m³	4.69	5 42		
lbs/hr	0.000761	5,43	9.91	6.68
Manganese	0.000701	0.000886	0.001610	0.001086
ug/m <sup>3</sup>				The second of th
lbs/hr	0.000164	1.09	1.30	1.13
Vickel	0.000104	0.000177	0.000212	0.000184
ug/m <sup>3</sup>	0.74			2 careto Again
lbs/hr		1.03	0.53	0.77
dercury	0.000120	0.000168	0.000086	0.000125
ug/m³	19.92	20.5		1-3-2
lbs/hr		30.6	25.4	25.31
ilver	0.00322	0.00496	0.00415	0.00411
ug/m <sup>3</sup>	ND	NTS	1:0:	3.4
lbs/hr	ND ND	ND	0.22	<0.22
xbaust Flow		ND	0.000036	<0.000036
acfm		C	الإنجاب الأصف سن البريسية الدور	
dscfm	49,017	48,937	49,073	49,009
~~*************************************	43,297	43,561	43,357	43,405

y 11-23

## TABLE 4 SUMMARY OF SPECIATED ORGANICS AIR POLLUTION CONTROL SYSTEM SCRUBBER EXHAUST SA RECYCLING TERMINAL ISLAND FACILITY

Conducted On: June 18, 2012

1

Towns of

17.1

Parameter:	Run No. 1	Run No. 2	Run No. 3	Average
Benzene		र स्वरूप्तर <del>वर्षे</del> कर कर , कर		
ppb v/v	4.3	7.9	15.0	9.1
lbs/hr	0.0023	0.0042	0.0079	0.0040
Ethylbenzene			0.0075	0.0048
ppb v/v	9.4	6.6	9,3	8.4
lbs/hr	0.0067	0.0047	0.0067	0.0060
1,1-Dichloroethene			7.0007	0.0000
ppb v/v	15	23	42	27
lbs/hr	0.0098	0.0150	0.0275	0.0174
Chloromethane		0.0150	0.0275	0.0174
ppb v/v	9.7	19	31	
lbs/hr	0.0033	0.0065	0.0106	20 0.0068
Trichlorofluoromethane		V.0003	0.0100	0.0068
ppb v/v	360	400	720	
lbs/hr	0.3335	0.3706	0.6671	493
Dichlorodifluoromethane		0.5700	0.0071	0.4571
ppb v/v	410	420	<u> </u>	410
lbs/hr	0.3318	0.3398	400	410
1,2,4-Trimethylbenzene		0.3376	0.3237	0.3317
ppb v/v	12	11	15	
lbs/lır	0.0097	0.0089	<del></del>	13
Toluene	7. 7. 7. 7. 7. 7. 7. 7. 7. 7. 7. 7. 7. 7	0.0009	0.0122	0.0103
ppb v/v	19	26		
lbs/br	0.0118	0.0161	45	30
1,3,5-Trimethylbenzene	0.0118		0.0279	0.0186
ppb v/v	3.6	2.2		
lbs/hr	0.0029	3.3	4.8	3.9
n,p-Xylene	0.0029	0.0027	0.0039	0.0032
ppb v/v	37	25		
lbs/hr	0.0265	0.0179	37	33
2-Xylene	0.0205	0.0179	0.0265	0.0236
ppb v/v	12	9.4		
lbs/hr	0.0086		14	11.8
-Ethyltoluene	0.0080	0.0067	0.0100	0.0084
ppb v/v	3.4	6.6	الملحية المستسنة	10007 10007
lbs/hr	0.0028	0.0053	9.3	6.4
Exhaust Flow	0.0028	0.0033	0.0075	0.0052
actin	49,017		40.107	
dscfm	43,297	49,017 43,297	49,107	49,017

e not done

#### TABLE 5

#### SUMMARY OF HF AND HCL DATA AIR POLLUTION CONTROL SYSTEM SCRUBBER EXHAUST SA RECYCLING TERMINAL ISLAND FACILITY

Conducted On: June 18-19, 2012

Parameter:	Run No. 1	Run No. 2	Run No. 3	Average
HF	THE STATE OF THE S		<del></del>	
grains/dscf	0.0001	< 0.0001	0.0001	<0.0001
lbs/hr	0.027	0.015	0,020	<0.021
HCL				1.2.
grains/dscf	0.0003	0.0003	0.0003	0.0003
lbs/hr	0.106	0.119	0.121	0.116
Exhaust Flow		**************************************		
dscfm	42,980	43,097	42,870	42,982